

# Glass and Glazing Federation

Certifies that

*CPFilms*

Certificate No: *TC0168*

NUV65 SR PS4 120 micron LLumar solar control safety film has passed Class 3B3 of BS EN 12600 'Glass in Building – Pendulum Test – Impact Test Method and Classification for Flat Glass' on 3 mm float glass

Tested at Wintech Engineering Ltd, UKAS Accredited Test Laboratory, No.2223


Issued: *24 April 2003*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WINTech Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585