

Glass and Glazing Federation

Certifies that

CPFilms

Certificate No: ***TC0123***

SSI SR PS4 125 micron LLumar solar control safety film has passed Class 2B2 of BS EN 12600 'Glass in Building – Pendulum Test – Impact Test Method and Classification for Flat Glass' on 3 mm float glass

Tested at Wintech Engineering Ltd, UKAS Accredited Test Laboratory, No.2223


Issued: ***1 December 2002***

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation
44 – 48 Borough High Street
London
SE1 1XB
Tel: 020 7207 5872
Fax: 020 7357 7458

Test Facility:
WINTECH Engineering Ltd
Halesfield 2
Telford TF7 4QH
Tel: 01952 586580
Fax: 01952 586585